

administrator's validation mark and the manufacturer's certification of compliance with the applicable standards are required to be on the certification label issued by the administrator to the manufacturer. In the case of solid fuel type room heaters and fireplace stoves, the following additional information must be included on the certification label:

- (i) The manufacturer's statement of conformance to the HUD Building Products Certification Program;
- (ii) The manufacturer's name and the identity and location of manufacturing plant;
- (iii) The specification designation and manufacturer series or model number; and
- (iv) The type of fuel to be used.

(2) The certification label must be permanently affixed to the heater or stove and be readily visible after the heater or stove is installed.

(c) *Periodic tests and quality control inspections.* Under the procedures set forth in paragraph (d)(8) of § 200.935, concerning periodic tests and quality control inspections, the frequency of testing for a product must be described in the specific building product certification program. In the case of solid fuel type room heaters and fireplace stoves, testing and inspection shall be conducted as follows:

(1) Once every four years, beginning with the initial administrator visit, a sample of each certified product shall be selected by the administrator for testing for compliance with the applicable standards in a laboratory which has been accredited under the National Voluntary Laboratory Accreditation Program.

(2) The administrator shall visit the manufacturer's facility two times a year to assure that the initially accepted quality control procedures are being followed.

[48 FR 1955, Jan. 17, 1983]

§ 200.937 Supplementary specific procedural requirements under HUD building product standards and certification program for plastic bathtub units, plastic shower receptors and stalls, plastic lavatories, plastic water closet bowls and tanks.

(a) *Applicable standards.* (1) Plastic bathtub units, plastic shower receptors and stalls, plastic lavatories, and plastic water closet bowls and tanks shall be designed, assembled and tested in compliance with the following standards, which are incorporated by reference:

ANSI Z124.1—(1980) Plastic Bathtub Units
ANSI Z124.2—(1980) Plastic Shower Receptors and Stalls
ANSI Z124.3—(1980) Plastic Lavatories
ANSI Z124.4—(1983) Plastic Water Closet Bowls and Tanks

(2) These standards have been approved by the Director of the Federal Register for incorporation by reference. They are available from the American National Standards Institute, Inc., 11 West 42nd Street, New York, NY 10036. The standards are also available for inspection at the Office of the Federal Register, 800 North Capitol Street, NW., suite 700, Washington DC 20408.

(b) *Labeling.* (1) Under the procedures set forth in paragraph (d)(6) of § 200.935, concerning labeling of a product, the administrator's validation mark and the manufacturer's certification of compliance with the applicable standards are required to be on the certification label issued by the administrator to the manufacturer. In the case of plastic bathtub units, plastic shower receptors and stalls, plastic lavatories, and plastic water closet bowls and tanks, the following additional information shall be included on the certification label:

(i) Manufacturer's statement of conformance to UM 73a;

(ii) Manufacturer's name and code identifying the plant location.

(2) The certification label shall be affixed to each plastic bathroom fixture.

(c) *Periodic tests and quality control inspections.* Under the procedures set forth in paragraph (d)(8) of §200.935, concerning periodic tests and quality control inspections, the frequency of testing for a product shall be described in the specific building product certification program. In the case of plastic bathroom fixtures, testing and inspection shall be conducted as follows:

(1) At least every six months, the administrator shall visit the manufacturer's facility to select a sample of each certified plastic bathtub unit, plastic shower receptor and stall, plastic water closet bowl and tank for testing in an approved laboratory, in accordance with applicable standards.

(2) At least every twelve months, the administrator shall visit the manufacturer's facility to select a sample of each certified plastic lavatory for testing in accordance with applicable standards.

(3) The administrator shall also review quality control procedures at each visit to determine that they continue to be followed.

[49 FR 378, Jan. 4, 1984, as amended at 59 FR 36695, July 19, 1994]

§200.938 Supplementary specific requirements under the HUD Building Product Standards and Certification Program for Aluminum Fenestration Products.

(a) *Applicable Standards.* (1) All aluminum fenestration products shall be designed, manufactured, and tested in compliance with the following American National Standards Institute and American Architectural Manufacturers Association standards:

(i) ANSI/AAMA 101-93—Voluntary Specifications for Aluminum and Poly (vinyl/ chloride) (PVC) Prime Windows and Glass Doors;

(ii) ANSI/AAMA 1102.7-89—Voluntary Specifications for Aluminum Storm Doors;

(iii) ANSI/AAMA 1002.10-93—Voluntary Specifications for Insulating Storm Products for Windows and Sliding Glass Doors;

(iv) AAMA 1600-90—Voluntary Specification for Skylights.

(2) These standards have been approved by the Director of the Federal Register for incorporation by ref-

erence. The standards are available from the American Architectural Manufacturers Association, 35 East Wacker Drive, Chicago, IL 60601 or the American Material Standards Institute, Inc., 11 West 42nd Street, New York, NY 10036. These standards are also available for inspection at the Office of the Federal Register, 800 North Capitol Street, NW., 7th Floor, suite 700, Washington, DC.

(b) *Labeling.* Under the procedures set forth in §200.935(d)(6) concerning labeling of a product, the administrator's validation mark and the manufacturer's certification of compliance with the applicable standards are required to be on the certification label issued by the Administrator to the manufacturer. Each aluminum fenestration product shall be marked as conforming to UM 39b. The label shall be located on each aluminum fenestration product so that it is available for inspection. The label shall include the manufacturer's name and plant location.

(c) *Periodic tests and quality assurance inspections.* Under the procedure set forth in §200.935(d)(8) concerning periodic tests and quality assurance inspections, the frequency of testing for a product shall be described in the specific building product certification program. In the case of aluminum fenestration products, testing and inspection shall be conducted as follows:

(1) At least once every four years, the administrator shall visit the manufacturer's facility to select a sample, of the maximum size commercially available, for testing in a laboratory approved by the administrator.

(2) The administrator also shall review the quality assurance procedures twice a year to assure that they are being followed by the manufacturer.

[58 FR 67673, Dec. 22, 1993]

§200.939 Supplementary specific requirements under the HUD Building Product Standards and Certification Program for Wood Fenestration Products.

(a) *Applicable standards.* (1) All wood fenestration products shall be designed, manufactured, and tested in compliance with the following National Wood Window and Door Association standards: